



**NOTE:**

- 1- SHEET THICK 2mm(MINIMUM)
- 2- PAINT THICKNESS 100 -120MICRON FINSH RAL 7032
- 3- GEN. TOLERANCES FOR ALL DIMENSIONS IS ± 5mm
- 4- MAIN COPPER B/BAR (40x10) & E/BAR (25x5).
- 5- E/SWITCH INTERLOCK WITH VCB.
- 6- ALL RISER &BUBAR ARE SLEVED .
- 7- ALL HARDWARE USE 8.8 GRADE .
- 8- MID MOUNT CASSETTE TYPE VCB

**LEGEND:**

Dev. No.	Description
-F51/51N	O/C & E/F RELAY,
-P1	AM-METER
-S69	AM-METER SELECTOR SWITCH.
-H2	CAPACITIVE VOLTAGE INDICATOR
-S68	AUTO/OFF/MANUAL SELECTOR SWITCH FOR PANEL HEATER
-H1	INDICATION LAMPS

We reserve all rights in this document and in the information contained therein. Reproduction, use or disclosure to third parties without express authority is strictly forbidden. © PAK ELEKTRON LTD. (PEL)

Prepared	RIZWAN	CHECKED	E/H	11KV VCB PANEL CASSETTE TYPE WITHOUT METERING (TYPE 2) GENERAL ARRANGEMENT	Department SWITCHGEAR DESIGN	Rev.	File Ref.:
Approved	NS/E.H						
CUSTOMER:- K- ELECTRIC LIMITED				<b>Pak Elektron Ltd.</b> 14-KM, FERAZEPUR ROAD-LAHORE, PAKISTAN	DRAWING NUMBER	D 396 2840	Sheet
Rev.	Revision	Name	Date				Cont